

Date : 11/08/2022

Server Technology, Inc.
1040 Sandhill Rd
Reno NV 89521
USA

Attn: Joseph McGuire

Re. : CU US + Canada Certificate

Type of Equipment : Power Distribution Unit
Model Designation : See Certificate
Certificate No. : CU 72228298 0001
File No. : 31381497 319
Engineer/Contact : Amir Riahejad
Standard(s) : UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Dear Mr. McGuire,

The above referenced technical equipment has been tested and was found to be in accordance with the listed test requirement(s). Enclosed, please find the TUV Rheinland Certification document No. CU 72228298 0001.

Please forward the original to the license holder.

Call the TUV hotline at 1-TUV-Rheinland (1-888-743-4652) to get answers for all your compliance needs.

If we can be of any further assistance to you, please do not hesitate to contact us.

Sincerely yours,
Certification Body

Dipl.-Ing. M. Glagla
QA Certification Officer

Enclosure

TUV Rheinland
of North America, Inc.

295 Foster St.
Suite 100
Littleton, MA 01460

Tel 978-266-9500
Fax 978-266-9992
Toll Free TUV-RHEINLAND
Mail info@tuv.com
Web www.tuv.com

Member of
TUV Rheinland Group

Date : 11/08/2022

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA
Attn: Joseph McGuire

Re. : CU US + Canada Certificate

Type of Equipment : Power Distribution Unit
Model Designation : See Certificate
Certificate No. : CU 72228298 0001
File No. : 31381497 319
Engineer/Contact : Amir Riahinejad
Standard(s) : UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Dear Mr. McGuire,

The above referenced technical equipment has been tested and was found to be in compliance with the listed test requirement(s). Enclosed, please find the TUV Rheinland approval document No. CU 72228298 0001.

It authorizes you to label the listed product(s) with the TUV Rheinland Mark identified in the approval document. For compliance, the Test Mark must be on the approved unit.

Your product is subject to regular factory follow-up inspections as well as annual certificate and factory registration fees.

In using the TUV Rheinland Mark you are obligated to comply with the TUV Rheinland of North America Service Agreement.

If we can be of any further assistance to you, please do not hesitate to contact us.

Sincerely yours,
Certification Body

Dipl.-Ing. M. Glagla
QA Certification Officer

Enclosure

TUV Rheinland
of North America, Inc.

295 Foster St.
Suite 100
Littleton, MA 01460

Tel 978-266-9500
Fax 978-266-9992
Toll Free TUV-RHEINLAND
Mail info@tuv.com
Web www.tuv.com

Member of
TUV Rheinland Group

Certificate



Certificate no.

CU 72228298 01

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

Server Technology, Inc.
1040 Sandhill Rd
Reno NV 89521
USA

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Model Designation: 1) C2Mabcd-efghijklpqrstu/mnovwy,
C2Sabcd-efghijklpqrstu/mnovwy,
C2Labcd-efghijklpqrstu/mnovwy,
C2SGabcd-efghijklpqrstu/mnovwy,
C2LGabcd-efghijklpqrstu/mnovwy,
C2WSabcd-efghijklpqrstu/mnovwy,
C2XSabcd-efghijklpqrstu/mnovwy,
C2Wabcd-efghijklpqrstu/mnovwy,
C2Xabcd-efghijklpqrstu/mnovwy,
C2WGabcd-efghijklpqrstu/mnovwy,
C2XGabcd-efghijklpqrstu/mnovwy,
C2Babcd-efghijklpqrstu/mnovwy, contd.

Appendix: 1, 1-77

Licensed Test mark:



**Date of Issue
(day/mo/yr)**

08/11/2022

Certificate



Certificate no.

CU 72228298 02

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

KeyTronic Juarez
Calle Magneto, Esg Con Dorados # 7824
32380 Chihuahua, CD. Juarez
MEXICO

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Model Designation: (contd.)

2) C2Mabcd-efghijklpqrstu-xxx/mnovwy,
C2Sabcd-efghijklpqrstu-xxx/mnovwy,
C2Labcd-efghijklpqrstu-xxx/mnovwy,
C2SGabcd-efghijklpqrstu-xxx/mnovwy,
C2LGabcd-efghijklpqrstu-xxx/mnovwy,
C2WSabcd-efghijklpqrstu-xxx/mnovwy,
C2XSabcd-efghijklpqrstu-xxx/mnovwy,
C2Wabcd-efghijklpqrstu-xxx/mnovwy,
C2Xabcd-efghijklpqrstu-xxx/mnovwy,
C2WGabcd-efghijklpqrstu-xxx/mnovwy,

Additional Manufacturing Plant: (K2220308) contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022

Certificate



Certificate no.

CU 72228298 03

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

SMTC de Chihuahua S.A de C.V
Washington, Building 20 No. 3701
31200 Chihuahua, Chihuahua C.P.
MEXICO

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Model Designation: (contd.)

- 2) C2XGabcd-efghijklpqrstu-xxx/mnovwy,
C2Babcd-efghijklpqrstu-xxx/mnovwy,
- 3) C1Mabcd-efghijklpqrstu/mnovwy,
C1Sabcd-efghijklpqrstu/mnovwy,
C1Labcd-efghijklpqrstu/mnovwy,
C1SGabcd-efghijklpqrstu/mnovwy,
C1LGabcd-efghijklpqrstu/mnovwy,
C1WSabcd-efghijklpqrstu/mnovwy,
C1XSabcd-efghijklpqrstu/mnovwy,
C1Wabcd-efghijklpqrstu/mnovwy,

Additional Manufacturing Plant: see above (K2220096) contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022

Certificate



Certificate no.

CU 72228298 04

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

CHING LEEN ELECTRONICS CO., LTD.
No.3, Minsheng St, Tucheng Dist.
New Taipei City 23679
Taiwan, R.O.C.

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Model Designation: (contd.)

- 3) C1Xabcd-efghijklpqrstu/mnovwy,
C1Wabcd-efghijklpqrstu/mnovwy,
C1Xabcd-efghijklpqrstu/mnovwy,
C1Babcd-efghijklpqrstu/mnovwy
- 4) C1Mabcd-efghijklpqrstu-xxx/mnovwy,
C1Sabcd-efghijklpqrstu-xxx/mnovwy,
C1Labcd-efghijklpqrstu-xxx/mnovwy,
C1SGabcd-efghijklpqrstu-xxx/mnovwy,
C1LGabcd-efghijklpqrstu-xxx/mnovwy,
C1WSabcd-efghijklpqrstu-xxx/mnovwy,

Additional Manufacturing Plant: see above (K2239263) contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022

Certificate



Certificate no.

CU 72228298 05

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

Server Technology, Inc.
1040 Sandhill Rd
Reno NV 89521
USA

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Model Designation: (contd.)

- 4) C1XSabcd-efghijklpqrstu-xxx/mnovwy,
C1Wabcd-efghijklpqrstu-xxx/mnovwy,
C1Xabcd-efghijklpqrstu-xxx/mnovwy,
C1WGabcd-efghijklpqrstu-xxx/mnovwy,
C1XGabcd-efghijklpqrstu-xxx/mnovwy,
C1Babcd-efghijklpqrstu-xxx/mnovwy
- 5) C3Mabcd-efghijklpqrstu/mnovwy,
C3Sabcd-efghijklpqrstu/mnovwy,
C3Labcd-efghijklpqrstu/mnovwy,
C3SGabcd-efghijklpqrstu/mnovwy,

contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022

Certificate



Certificate no.

CU 72228298 06

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

KeyTronic Juarez
Calle Magneto, Esg Con Dorados # 7824
32380 Chihuahua, CD. Juarez
MEXICO

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Model Designation: (contd.)

- 5) C3LGabcd-efghijklpqrstu/mnovwy,
C3WSabcd-efghijklpqrstu/mnovwy,
C3XSabcd-efghijklpqrstu/mnovwy,
C3Wabcd-efghijklpqrstu/mnovwy,
C3Xabcd-efghijklpqrstu/mnovwy,
C3WGabcd-efghijklpqrstu/mnovwy,
C3XGabcd-efghijklpqrstu/mnovwy,
C3Babcd-efghijklpqrstu/mnovwy,
6) C3Mabcd-efghijklpqrstu-xxx/mnovwy,
C3Sabcd-efghijklpqrstu-xxx/mnovwy,
contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022

Certificate



Certificate no.

CU 72228298 07

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

SMTC de Chihuahua S.A de C.V
Washington, Building 20 No. 3701
31200 Chihuahua, Chihuahua C.P.
MEXICO

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Model Designation: (contd.)

6) C3Labcd-efghijklpqrstu-xxx/mnovwy,
C3SGabcd-efghijklpqrstu-xxx/mnovwy,
C3LGabcd-efghijklpqrstu-xxx/mnovwy,
C3WSabcd-efghijklpqrstu-xxx/mnovwy,
C3XSabcd-efghijklpqrstu-xxx/mnovwy,
C3Wabcd-efghijklpqrstu-xxx/mnovwy,
C3Xabcd-efghijklpqrstu-xxx/mnovwy,
C3WGabcd-efghijklpqrstu-xxx/mnovwy,
C3XGabcd-efghijklpqrstu-xxx/mnovwy,
C3Babcd-efghijklpqrstu-xxx/mnovwy
contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)
08/11/2022

Certificate



Certificate no.

CU 72228298 08

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

CHING LEEN ELECTRONICS CO., LTD.
No.3, Minsheng St, Tucheng Dist.
New Taipei City 23679
Taiwan, R.O.C.

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Model Designation:(contd.)

ab = 02-84;cd = VA#VF, VH, VJ-VN, VP, VR,VS, VT, VW, VY,
VX, RG, RQ, RX, CA-CF, CS, CT, EA, ,TS, TF, TE, TD,
TB, TC, TA, RL; ef = 01, 02, 0A, 0P, 11, 12,
1A-1E, 1J, 21, 22, 23, 25, 2A-2H, 2J, 2K,2M, 2N, 2P, 2Q,
31, 32, 3B, 3C, D1-D7, D8, DB-DI, DN, DP-DS, DT,
Y1-Y4, YB, YC, YG, YH, YN, YP-YS,
51-55, 5B, 5C, 5D, 5E, 5G, 5H, 5L, 5N, 5P-5S,
GA, GD, GG, GH, GN, GP, RB, 61, 62, 7A, 8A, 8B, 8C,
8D, 8E, 8F, 8G, 8H, 8N, 8T, 8U, 9P, 9Q;
gh = 00, 0A, F1-F3, FA, FN, FP-FS, FV, BA-BH,
BJ-BN, BP-BS, HA-HH, HJ, HK, IA,

contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022

Certificate



Certificate no.

CU 72228298 09

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

Server Technology, Inc.
1040 Sandhill Rd
Reno NV 89521
USA

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Model Designation: (contd.)

CA-CH, CJ, CK, JA-JH, JJ-JN, JP-JR LA-LH, LJ-LN, LP-LR
EA-EH, EJ, EK, GA-GH, GN, GP-GV, KA-KH, KJ-KN, KP-KR,
AA-AH, AJ-AM, DA-DH, DJ-DN, DP-DS, MA-MH, MJ-MM,
NA-NH, NK-NM, PA-PH, PL, PJ, PK; i = 0-6, A, O;
j = 0, 1-4, 5-9, A, B, K, L, M, N, S, E, F, G, H, J,
O, R, T, U; k1 = AC, A0-A9, B1-B8, C1-C9, D1-D9, E1-E9,
F1-F9, G1-G8, G9, H1-H4, HA, Z1, J1, J2, J3, J4,
J5, J6, T0, T1, T2, T3, T4, blank;
p, q, r, s, t, u = 0-9, blank;
m, n, o, v, w, x, y = 0-9, A-Z, blank)

contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022

Certificate



Certificate no.

CU 72228298 10

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

KeyTronic Juarez
Calle Magneto, Esg Con Dorados # 7824
32380 Chihuahua, CD. Juarez
MEXICO

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

contd. Rated Voltage 1) - 6)
AC 100-240V or 110-240V or 220-240V, 50/60Hz,
(for e = 0)
AC 100-120V or 110-120V or 120V, 50/60Hz,
(for e = 1)
AC 200-240V or 208-240V or 220-240V, 50/60Hz,
(for e = 2)
AC 120/208V or 120/240V, 50/60Hz,
(for e = 3)
3/PE AC 200V or 208V or 208-240V, 50/60Hz,
(for e = D)

contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022

Certificate



Certificate no.

CU 72228298 11

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

SMTC de Chihuahua S.A de C.V
Washington, Building 20 No. 3701
31200 Chihuahua, Chihuahua C.P.
MEXICO

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Rated Voltage: (contd.)

3/N/PE AC 120/208V, 50/60Hz,
(for e = Y)
3/N/PE AC 220/380V - 240/415V, 50/60Hz,
(for e = 5)
3/N/PE AC 220/380V-240/415V, 50/60Hz,
(for e = G)
AC 277V, 50/60Hz,
(for e = 6)
3/PE AC 200V, 208-240V, 50/60Hz
(for e = 7)

contd.

Licensed Test mark:



**Date of Issue
(day/mo/yr)**

08/11/2022

Certificate



Certificate no.

CU 72228298 12

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

CHING LEEN ELECTRONICS CO., LTD.
No.3, Minsheng St, Tucheng Dist.
New Taipei City 23679
Taiwan, R.O.C.

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Rated Voltage (contd.)

3/N/PE AC 220/380V - 240/415V or
240/415V, 3/N/PE AC 120/208V,
3/PE 200V or 208V or 208-240V or 200-240V,
2/PE 208-240V or 200V or 200-240V, 50/60Hz,
(for e = 8)
3/N/PE AC 277V/480V, 50/60Hz,
(for e = 9)
3/N/PE AC 220/380V-240/415V, 50/60Hz,
(for e = R)

contd.

Licensed Test mark:



**Date of Issue
(day/mo/yr)**

08/11/2022

Certificate



Certificate no.

CU 72228298 13

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

Server Technology, Inc.
1040 Sandhill Rd
Reno NV 89521
USA

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Rated Current: (contd.) 1)-6)

16A or 20A or 24A or 30A or 32A

(for e = 0);

12A or 15A or 16A or 20A or 24A or 30A

(for e = 1);

16A or 20A or 24A or 30A or 32A or 40A or 48A or

50A or 60A (for e = 2);

16A or 20A or 24A or 30A (for e = 3);

16A or 20A or 24A or 30A or 35A or 40A or 48A or 50A

60A or 80A or 100A (for e = D);

contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022

Certificate



Certificate no.

CU 72228298 14

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

KeyTronic Juarez
Calle Magneto, Esg Con Dorados # 7824
32380 Chihuahua, CD. Juarez
MEXICO

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Rated Current: contd.

16A or 20A or 24A or 30A or 40A or 48A or 60A or 80A or 100A
(for e = Y);

16A or 20A or 24A or 30A or 48A or 50A or 60A or 80A or 100A
(for e = 5);

16A or 20A or 24A or 30A or 32A or 60A or 63A
(for e = G);

16A or 20A or 24A or 30A (for e = 6);
30A (for e = 7);

16A or 20A or 24A or 30A or 32A or 40A or 48A or 50A or 60A
(for e = 8)

contd.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022

Certificate



Certificate no.

CU 72228298 15

License Holder:

Legrand DPC LLC dba
Server Technology
60 Woodlawn Street
West Hartford CT 06110
USA

Manufacturing Plant:

SMTC de Chihuahua S.A de C.V
Washington, Building 20 No. 3701
31200 Chihuahua, Chihuahua C.P.
MEXICO

Test report no.: USA-ar 31381497 319

Client Reference: Joseph McGuire

Tested to: UL 62368-1:2019
CSA C22.2 NO. 62368-1:19

Certified Product: Power Distribution Unit

License Fee - Units

Rated Current: contd.
24A or 30A or 48A or 60A
(for e = 9);
32A, 40A or 63A
(for e = R)

Protection Class: I

Rated Ambient Temperature: 40° to 65°C max.

Special Remarks: Replaces Certificate CU72225076.

Licensed Test mark:



Date of Issue
(day/mo/yr)

08/11/2022